



STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



Facility Information Section

Satisfactory

Permit Number: 13-51-08338
Type: Public School
Owner: M-DCSB Food and Nutrition
Person In Charge: Allen Breeding Phone: (305) 995-3800
Name of Facility: W.R. Thomas Middle School
Address: 13001 SW 26 Street
City, Zip: Miami 33175

Inspection Results Information Section

Purpose: Complaint	Begin Time: 04:00 PM	Correct By: None
Inspection Date: 3/30/2016	End Time: 05:00 PM	Re-Inspection Date: None

Additional Information Section

CENSUS	1199
FEMALES	613
MALES	586

As per section 120.695 of the Florida Statutes (FS), this form will serve as a "Notice of Non-Compliance: for any violations noted. Items marked below violate the requirements of Chapters 64E-13 and 64E-11 of the Florida Administrative Code (FAC) and must be corrected within the time period indicated in the "Results" section above. Continued operation of this facility without making these corrections is a violation of Chapter 64E-13 and 64E-11, FAC, and Chapter 381, FS. Failure to correct violations may result in an administrative fine or other legal action being initiated or continued.

Violation Markings Section

SCHOOL SANITATION	11. Cleanliness & Repair	22. Solid Waste
1. School Site	12. Toilet Facilities	VECTOR/VERMIN CONTROL
2. Playground Equipment	13. Separation of Sexes	23. Infestation/Control
3. Athletic Equipment	14. Fixture Ratio	24. Brush/Trash
BUILDINGS	15. Handwash Facilities	25. Water Collection/Drainage
4. Construction	16. Showers/Fixtures	SAFETY
5. Maintenance & Repair	17. Shower Water Temp.	26. First Aid Kit
6. Lighting/Foot-Candles	WATER SUPPLY	FOOD
7. Heating, Ventilation, A/C	18. Installed/Operated/Maintained	27. Food Insp. Rpt.
8. Natural Ventilation	19. Drinking Fountains	OTHER
9. Mechanical Ventilation	20. Approved Source	28.
SANITARY FACILITIES	LIQUID/SOLID WASTE	29.
10. Provided/Accessible	21. Sewage Disposal	

General Comments Section

Inspector Signature:

Client Signature:



STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

This inspection is in response to an anonymous complaint received on 03/29/ 2016 which alleged that "there is no air conditioning in the school. The classroom has no windows and no ventilation. The fan in use is broken and has not being replaced. Being under this heat is not good for a child health"

I met the school principal Mr. Allen Breeding who explained that there was a slight problem with the A/C system two weeks ago due to the malfunction of one of the two chillers that caused that the temperature was slightly higher than normal as the system was relying in only one chiller, but the school was not without A/C as the complainant reported. The issue was resolved and the building temperatures have been in the normal range. Also according to Mr. Breeding at the beginning of the classes this week after the spring recess the school temperatures were slightly high on Monday morning until the A/C system could catch-up and reach the set temperatures.

At the time of the inspection the school building room temperatures were between 70.5 °F and 71.9 °F, measured in different areas of the building.

It is impossible to identify the particular room reported by the complainant without knowing the room number. The reported classroom "without windows" could be any of the 52 classrooms located in the main building.

At the time of the inspection the complaint is invalid.

Violations Comments Section

No Violation Comments Available

Inspection Conducted By: Osvaldo Samper (67699)
Phone: (305) 623-3500
Received By: Signed
Date: 3/30/2016

Inspector Signature:

A handwritten signature in black ink, appearing to be "OSVALDO".

Client Signature:

A handwritten signature in black ink, appearing to be "BREEDING".